



UConn
Project #901803
Gant Building Renovations – STEM
Phase 0 – Investigation and Mock-ups

Construction Bid – Addendum 4
October 4, 2016

A. General Requirements

When submitting your proposal, please indicate acknowledgement of this Addendum under “Addenda” in Exhibit G. Include any price adjustments necessary as a result of new/ revised bid documents under Exhibit G Pricing Schedule.

**Note all bids will be evaluated on best overall value which may include the alternate pricing.*

B. Attachments:

Please review all attachments in their entirety for inclusion into the base bid documents. All attachments can be downloaded from <https://whiting-turner.box.com/s/e9i8q1919exly4fqmn0e5yjpvsy9zgb>

1. RFI #1 Response.

<i>Bid due date: The bid date remains October 11, 2016 at 12:00 p.m.</i>

University of Connecticut
UConn Project #901803; Gant Building Renovations – STEM
Phase Zero – Investigations and Mockups
Storrs, Connecticut
October 4, 2016
Bid Clarifications and RFI's #1

RFI's:

1. Specification Section 084314 2.1 calls for an EfcO 403X storefront system which is 2" x 4-1/2" center set. Details on Z-200 show a 6-1/2" deep front set curtain wall. Could you please advise which is correct and to incorporate?

GCA Reply:
October 4, 2016

1) EFCO 403x storefront system is the basis of design as called out in specification section 084314 2.1.

Arjun Mande